




## ADDENDUM NO. 2

**TO:** All Planholders

**FROM:** Daniel R. Shafar, P.E.   
Project Engineer

**DATE:** May 9, 2012

**RE:** Skamania County PUD No. 1  
Carson Reservoir Coating Project  
WE Job No. 1321A

---

Notice is hereby given to prospective bidders that the Contract Documents have been amended as follows:

- **A copy of this addendum is available for download at the ENGINEER'S website:** <http://walliseng.net/login/>.

### **ITEM 1:**

CONTRACT DOCUMENTS, PART IV – TECHNICAL SPECIFICATIONS, DIVISION 9 – FINISHES, SECTION 09800 – PROTECTIVE COATINGS, PART 3 EXECUTION, 3.02 SAFETY AND HEALTH REQUIREMENTS, E. LEAD PAINT REMOVAL: Supplement the first paragraph with the following:

“The Contractor is responsible to meet all state and federal codes for the collecting, testing, and disposal of containment waste. The lead content tests provided by the PUD do not alleviate the Contractor of their responsibility to complete additional testing for compliance with applicable local, state, and federal regulations to ensure the waste is properly classified and disposed of.”

### **ITEM 2:**

CONTRACT DOCUMENTS, PART IV – TECHNICAL SPECIFICATIONS, DIVISION 9 – FINISHES, SECTION 09800 – PROTECTIVE COATINGS, PART 3 EXECUTION, 3.02 SAFETY AND HEALTH REQUIREMENTS, E. LEAD PAINT REMOVAL: Replace the second paragraph with:

“The Contractor shall be responsible for containment measures required to provide and maintain a safe and healthful jobsite in accordance with WAC 296-155-17605 and 29 CFR 1926.62. The Contractor shall also ensure that air flow is maintained in and out of the vent.”

**All bidders shall acknowledge receipt of this addendum by dating and signing the appropriate line in the Bid Proposal Form submitted with their bid.**